



ठाणे महानगरपालिका
THE MUNICIPAL CORPORATION OF THE CITY OF THANE
प्रदूषण नियंत्रण कक्ष
POLLUTION CONTROL CELL

E-mail : pcctmc@gmail.com
Tel : +91 -22 -25362916



महानगरपालिका भवन, सरसेनानी जनरल अरूणकुमार वैद्य मार्ग, चंदनवाडी, पांचपखाडी, ठाणे - ४००६०२

Ref./T.M.C./P.C.C./V.Lab - 3394
Sample No. : P1516

Date : 26-Feb-24

TMC/PCC/20/RO

Name Of the Organisation : M/s.B. S. Bane Intenational School

Address : Swami Vivekanand Nagar, Old Mhala Colony, Next To Vasant Vihar, Majiwada, Thane400610

E_mail ID :

Date of receiving Sample : 23 February 2024

Sample Collected by : B. S. Bane Intenational School

Type of Water Sample : Storage Drinking

Parameters	Results	Limits as per IS 10500
pH	7.60	6.5 8.5
Free Residual Chlorine	0.4	1 ppm
Turbidity	2.0	5 NTU
Chloride	30.0	250 mg/L
Total Hardness	58.00	300 mg/L
Total Coilform Bacteria (MPN)	0.00	0/100 mL
F-Coli	Absent	0/100 mL
E-Coli	Absent	0/100 mL

All results are in ppm except pH.

Remark : The Sample is Microbiologically & Chemically Potable.

Prepared By

26-Feb-24

Prabhakar Sonawale

Thane Municipal Corporation, Thane

Authorised by

26-Feb-24

Omsatyashiv Paralkar

Thane Municipal Corporation, Thane

This is the analysis report of the Storage Drinking Water sample received to our Vakratunda Laboratory on 23/2/2024. This further acknowledges that you have paid the charges Rs. 1205/- vide Receipt No.TMC/HQ/PLC/000328/23-24 dated 23.02.2024



PRINCIPAL
B. S. BANE INTERNATIONAL SCHOOL
THANE